

FORM "S"

(SEE RULE 88 (5))

Fire Audit Report

Year 2026-27

To

SR Saumya (Principal)

Carmel Convent Sr Sec School Near CRPF, NEEMUCH Madhya Pradesh 458441

Sir,

Sub: Submission of fire audit report of building name "**CARMEL CONVENT SR SEC SCHOOL NEEMUCH**" at Bungalow NO.-14,15,16 & 17 Near CRPF, NEEMUCH Madhya Pradesh 458441

I **Rohit Bamne** have inspected your building / premises on **11th SEPTEMBER 2026** and checked all Fire Equipment's / installations and have completed the fire Audit of the said Building / premises for which Fire Noc no. **NA** Date..... issued by fire authority.

According to the use and character of occupancy; the campus includes building as "EDUCATIONAL BUILDINGS" Plot area of the building is more than 1000sq. meter & less than 15 meter in height and School Configurations of Ground plus one or more storeys So that it is falls under sub-division (B-1) I)

Height of the building – 13 meters (approx.)

2. Details of fire system installed are as below: -

S.No.	Particular	Available/installed or not installed (as per requirements) (Give comments)	Comments for working of System (attach detail, if any)
1.	Access	Available	
1.	Wet Riser	Not required	
2.	Down Comer	Available	
3.	Hose Reel	Available	15 Nos.
4.	Automatic Sprinkler System	Not required	
5.	Yard Hydrant	Available	15 Nos.
6.	Underground Tank with Draw off connection	Available	With 45000 liters. Capacity & 1 Nos. "WELL" available for complex building tank.
7.	Terrace Tank	Available	With total 16000 liters. Capacity (2000x8 nos. tank) separate for firefighting & attached with 2 fire pumps
8.	Fire Pump	Available	2 Nos. fire pump, (7.5 HP. 560 LPM each capacity)
9.	Terrace Pump	Available	3 HP & 2 HP Booster pumps
10.	Fire Aid Fire Fighting Appliances	Available	fire extinguishers: - ABC type 6kg= 21 Nos.

			CO2 type 4.5kg= 13 Nos.
11.	Pressurization System	Available	Naturally Ventilated
12.	Auto detection System	Not required	AS PER NBC 2016 PART IV TABLE NO 7
13.	Manual Operated Electrical Fire Alarm system	Not required	AS PER NBC 2016 PART IV TABLE NO 7
14.	P.A. System with talk back facility	Available	
15.	Emergency Light	Available	
16.	Auto D.G. Set	Available	25 KVA CAPACITY
17.	Illuminated Exit Sign	Available	
18.	Means of Escape	Available	9 no's means of escape available all are unobstructed
19.	Compartmentation	Not Required	
20.	MCB/ELCB	Installed.	All floors separate distribution boards are there with MCB
21.	Fireman Switch in Lift	Not Required	There is no LIFT installed in the premises
22.	Hose Boxes with Delivery hose and Branches	Available	15 Nos. Hose Box (double door) 15 Nos. Branch Pipe 30 Nos. Hose Pipe
23.	Refuge Area	Not required	This is applicable for high rise Building
24.	Any other installation	Available	2 Nos. Fire Brigade connection

MAJOR OBSERVATION & RECOMMENDATION ARE AS FOLLOWS AS PER NBC 2016 PART IV TABLE NO 7-SUB DIVISION B-1 AND OTHER SAFETY MEASURES.

1. ELECTRICAL AUDIT REQUIRED BY AUTHORIZED PERSON WITH LOAD DISTRIBUTION AND BALANCING.
 2. As per our today's Visit, Quarterly Inspection & Maintenance OF Installed FIRE Fighting System required.
- It is Conclude that the Building Fire Protection System installed as per the NBC 2016 table no 7.

Date: 11th SEPTEMBER 2026
Valid till: -10th SEPTEMBER 2027

CERTIFICATE NUMBER: -GFS/11-09/2026

Name: -ROHIT BAMNE

Designation: -M.P. Government Authorized Fire Consultant/Lead Auditor

License No: -04/BFB/2021

Signature: -

ROHIT BAMNE
B.E. FIRE
MOB-9826033688
LIC. No.- 04/BFB/2021

MAJOR OBSERVATION
AND RECOMMENDATION

1. ELECTRICAL AUDIT

2. AS PER OUR TODAY'S VISIT,

QUARTERLY INSPECTION & MAINTENANCE

Date: 11th SEPTEMBER 2026

Valid till: -10th SEPTEMBER 2027

MAJOR OBSERVATION